

Control Configuration Selection for Uncertain Multivariable Systems

Supervisor: doc. Ing. Radek Matušů, Ph.D.

Consultant: ---

Department: CEBIA-Tech

Programme: Automatic Control and Informatics

Abstract:

Control of complex multivariable technological processes is usually based on two main approaches. The first methodology relies on a central controller, while the second approach uses a decentralized control structure. It seems that the current practice prefers decentralized control structures. Naturally, the selection of a suitable control configuration is a crucial task. During the last decades, various methods for appropriate input-output pairings have been developed. However, not so much attention has been paid so far to their performance under conditions of uncertainty, which can be considered in the linearized models of complicated plants. The thesis should be focused on the investigation of the impact of (various types of) uncertainty on the existing control configuration selection methods and, subsequently, on the improvement of a method(s) from the viewpoint of robustness.

Literature:

- [1] Khaki-Sedigh, A., Moaveni, B., Khaki-Sedigh, A., Moaveni, B. Control Configuration Selection of Nonlinear Multivariable Plants (pp. 139-172). 2009, Springer Berlin Heidelberg.
- [2] Pequito, S., Kar, S., Aguiar, A. P. A framework for structural input/output and control configuration selection in large-scale systems. IEEE Transactions on Automatic Control, 2015, 61(2), 303-318.
- [3] Shaker, H. R., Komareji, M. Control configuration selection for multivariable nonlinear systems. Industrial & Engineering Chemistry Research, 2012, 51(25), 8583-8587.
- [4] Kadhim, A. M., Castaño Arranz, M., Birk, W. Automated control configuration selection considering system uncertainties. Industrial & Engineering Chemistry Research, 2017, 56(12), 3347-3359.
- [5] Chen, D., Seborg, D. E. Relative gain array analysis for uncertain process models. AIChE journal, 2002, 48(2), 302-310.
- [6] Kariwala, V., Skogestad, S., Forbes, J. F. Relative gain array for norm-bounded uncertain systems. Industrial & engineering chemistry research, 2006, 45(5), 1751-1757.
- [7] Agustriyanto, R., Zhang, J. Obtaining the worst case RGA and RDGA for uncertain systems via optimization. In 2007 American Control Conference (pp. 5360-5365). 2007, IEEE.
- [8] Arranz, M. C., Birk, W. A new approach to the dynamic RGA analysis of uncertain systems. In 2008 IEEE International Conference on Computer-Aided Control Systems (pp. 365-370). 2008, IEEE.
- [9] Jain, A., Babu, B. V. RGA Analysis of Dynamic Process Models Under Uncertainty. In Proceedings of the Second International Conference on Soft Computing for Problem Solving (SocProS 2012), December 28-30, 2012 (pp. 447-456). Springer India.

[10] Liu, L., Tian, S., Xue, D., Zhang, T., Chen, Y., Zhang, S. A review of industrial MIMO decoupling control. *International Journal of Control, Automation and Systems*, 2019, 17, 1246-1254.

[11] Kozáková, A., Veselý, V., Kučera, V. Robust decentralized controller design based on equivalent subsystems. *Automatica*, 2019, 107, 29-35.

[12] Yousfi, M., Ben Njima, C., Garna, T. Decentralized robust control of nonlinear uncertain multivariable systems. *Arabian Journal for Science and Engineering*, 2021, 46, 9899-9924.